

**RHODE ISLAND
STATE BUILDING CODE**

SBC-19 State Fuel Gas Code

Effective August 1, 2007

Replaces SBC-19-2004
Dated September 1, 2004



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

**Department of Administration
BUILDING CODE STANDARDS COMMITTEE
One Capitol Hill
Providence, RI 02908-5859
(401) 222-3033
FAX NO (401)-222-2599**

THIS PAGE LEFT INTENTIONALLY BLANK

**Regulation SBC-19
State Fuel Gas Code
August 1, 2007**

The Building Code Standards Committee, in accordance with the rule making authority of Title 23, Chapter 23-27.3, Section 109.1, paragraphs a through c inclusive, has formally adopted and promulgated as the Rhode Island State Building Code, the provisions of the International Fuel Gas Code, 2006 edition, as published by the International Code Council, Inc. (I.C.C.), together with amendments thereto hereinafter set forth to the articles and sections of this code:

The provisions of Title 23, Chapter 27.3 of the General Laws of Rhode Island establishing administration and enforcement are hereby incorporated by reference. Regulatory Administration Chapter 1 immediately follows and is supplemental to the General Laws.

Editorial Note: Code users please note:

When purchasing or using the State Fuel Gas 2006 code, please take note of the particular printing edition. Errata to that printing edition is available on-line directly at no charge at www.iccsafe.org/cs/codes/errata.html or call the office of the State Building Code Commissioner at 401-222-3033 for further information.

Printed copies of the administrative and enforcement provisions of Title 23, Chapter 27.3 are available at the Office of the State Building Code Commission or on-line at www.rilim.state.ri.us/statutes/title23/23_27.3/index.htm.

The State Fuel Gas Code, 2006 Edition, is protected by the copyright that has been issued to the ICC. As a result, the State Building Code is not available in complete form to the public in an electronic format. The State Fuel Gas Code 2006 edition that is referred to within is contained in a printed volume and is also in an electronic format that have been published by the ICC under an exclusive license.

The Office of the State Building Code Commissioner has purchased volumes of these codes and they shall be distributed to Rhode Island cities and towns during the month of June 2007 so that local officials will have access to the code prior to the implementation of these rules on July 1, 2007.

In order to assure public access to this code the Office of the State Building Code Commissioner shall provide a copy of this code to the Rhode Island State Library, which is located on the second floor of the State House. In addition, all codes may be viewed during business hours at the Department of Administration's Library which is located on the fourth floor of the William E. Powers Building, One Capitol Hill, Providence.

The Legislative Regulation Committee approved adoption of this code on July 10, 2007.

By:

John P. Leyden

Executive Secretary

Rhode Island Building Code Standards Committee

THIS PAGE LEFT INTENTIONALLY BLANK

CHAIRMAN
Dana Newbrook, RA
Architect

VICE CHAIRMAN
Stephen C. Turner, PE
Public Member

EXECUTIVE COMMITTEE

Allan Durand
Builders Trades Council

Robert M. Stillings
Architect

Bruce Davey, PE
Structural Engineer

Russell Brown
Building Official

John Pagliaro
Building Official

James R. Carlson, RA
Public Member

David F. Palmisciano
Building Trades Council

G. Thomas Chabot
Electrical Contractor

Gordon W. Preiss, PE
Mechanical Engineer

Randy Collins, Jr., RLA
Landscape Architect

Marie Stoeckel
Public Health Official

Robert E. DeBlis, Jr.
Builder

Builder
Vacant

Paul DePace, PE
Representative for the Disabled

Building Official
Vacant

Donald Gagnon
Minimum Housing Inspector

Electrical Inspector
Vacant

John D. Gaskell ,PE
Electrical Engineer

Representative for the Disabled
Vacant

Leonard P. Gemma
Master Plumber

John P. Leyden
Building Commissioner
Executive Secretary

William Howe
Fire Official

Legal Counsel

THIS PAGE LEFT INTENTIONALLY BLANK

STATE BUILDING CODE REGULATIONS – 2007

The following list includes all regulations promulgated by the State Building Code Standards Committee. All regulations are available for a fee at the State Building Commission.

1.	Building Code.....	SBC-1-2007
2.	One and Two Dwelling Family Dwelling Code.....	SBC-2-2007
3.	Plumbing Code.....	SBC-3-2007
4.	Mechanical Code.....	SBC-4-2007
5.	Electrical Code.....	SBC-5-2006
6.	Reserved	SBC-6
7.	Reserved	SBC-7
8.	State Energy Code.....	SBC-8-2007
9.	Enforcement and Implementation Procedures for Projects Under the Jurisdiction of the State of Rhode Island.....	SBC-9
10.	Code Interpretations.....	SBC-10
11.	Certification of Building Officials, Building, Electrical, Plumbing and Mechanical Inspectors.....	SBC-11-2002
12.	New Materials and Methods of Construction.....	SBC-12
13.	State Building Code For Existing Schools.....	SBC-13
14.	Reserved	
15.	Reserved	
16.	Reserved	
17.	Public Buildings Accessibility Meeting Standards.....	SBC-17
18.	Native Lumber.....	SBC-18
19.	Fuel Gas Code.....	SBC-19-2007

THIS PAGE LEFT INTENTIONALLY BLANK

Format: These code changes follow numbering sequence and topics of the International Fuel Gas Code 2006 (first printing). All Provisions of IFGC 2006 are retained unless indicated as deleted or revised. Published errata is available from the ICC website dependent on this printing issue number and date.

Chapter 1

ADMINISTRATION

The following Rhode Island amendments are made to the sections of Chapter 1:

Delete IFG Code section 101.1 Title, and substitute the following:

101.1 Title. These regulations shall be known as The Rhode Island State Fuel Gas Code Regulation SBC-19-2006 hereafter referred to as " this code"

Add the following new section 101.1.1 referenced codes.

101.1.1 Referenced Codes. The other codes referenced elsewhere in this code shall be considered part of the requirements of this code to the prescribed extent of each such reference.

1. Electrical. The provisions of Rhode Island State Electrical Code SBC-5-2006 shall apply wherever referenced in this code as the ICC Electrical Code, and shall apply to the installation of electrical systems, including alterations, repairs, replacement, equipment, appliances, fixtures, fittings, and appurtenances thereto.

2. Mechanical. The provisions of the Rhode Island State Mechanical Code SBC-4-2006 shall apply wherever referenced in this code as the International Mechanical Code and shall apply to the installation, alterations, repairs and replacement of mechanical systems, including equipment, appliances, fixtures, fittings and/or appurtenances, including ventilating, heating, cooling, air-conditioning and refrigeration systems, incinerators and other energy-related systems.

3. Plumbing. The provisions of Rhode Island State Plumbing Code SBC-3-2006 shall apply wherever referenced in this code as the International Plumbing Code, and shall apply to the installation, alteration, repair and replacement of plumbing systems, including equipment, appliances, fixtures, fittings and appurtenances, and where connected to a water or sewage system and all aspects of a medical gas system.

4. Property Maintenance. Refer to state or local codes.

5. Fire Prevention Code. Wherever and whenever provisions of the International Fire Code 2003 editions are referenced, the appropriate Rhode Island Fire Safety Code requirements shall apply.

6. **Energy Code.** The provisions of the Rhode Island State Energy Conservation Code SBC-8-2006 shall apply wherever referenced in this code as International Energy Conservation Code, and shall apply to all matters governing the design and construction of buildings for energy efficiency.
7. **Building Code.** The provisions of the Rhode Island State Building Code SBC-1-2006 shall apply wherever referenced in this code as the International Building Code.
8. **Residential Code.** The provisions of the Rhode Island One and Two Family Dwelling Code SBC-2-2006 shall apply wherever referenced in this code as the International Residential Code.
9. **Existing Building Code.** The provisions of the State Building Codes SBC-1-2006 in conjunction with the State Rehabilitation Code SRC-1 and the Rhode Island Fire Safety Code shall apply wherever referenced in this code as the International Existing Building Code.

Any and all such references to the various International Code Council family of code shall be substituted for the appropriate state code as indicated above.

101.2.4 Systems and equipment outside the scope.

Delete exception #9 and substitute the following:

9. Liquefied Natural Gas (LNG) installations shall be installed in accordance with this code and the Rhode Island Fire Safety Code.

Delete IFG Code section 101.3 and substitute the following:

101.3 Appendices. Provisions in the appendices are permitted to be used for determining compliance to this code.

Delete IFG Code sections 103, 104, 106.4.3 through 106 .5.3 and 108 through 109.7.

CHAPTER 3

Section 303 Appliance Location

Add the following new exception:

303.3. 6 Gas fired appliances may be installed in loft or open efficiency type apartments when there is a sleeping area not a sleeping room. The installation of appliances must comply with section 304.5 for combustion air required volume and the manufacturers' installation instructions.

THIS PAGE INTENTIONALLY LEFT BLANK

Chapter 4

401.2 Liquefied Petroleum Gas & Storage.

The storage system for liquefied petroleum gas shall be designed and installed in accordance with NFPA 58 and the following.

401.2.1

For LNG facilities exceeding 1,000 gallons equivalent water capacity structural engineering design by a licensed RI professional engineer shall include explicit analyses of seismic, storm, and hurricane impacts including combined wind and storm surge effects on tank, facility, dock and other associated structure and underlying foundation, pilings, piers, footings or other associated supports or ground connections.

401.2.2

Spill leak, escape and other failure analyses shall include mapping of impacts on surrounding existing structures and build able parcels to the distance determined by the engineer of record to delimit potential flame or heat impacts that could potentially impact tenability and structural stability of structures, whether adjacent to or beyond the LNG facility site. Such impacts shall be with respect to worse-case spill or release scenarios, not less than 14,000 cubic meters of LNG.

401.2.3

Site-specific analyses shall be performed of potential adverse impacts within the distance determined by the engineer of record to delimit potential flame or heat impacts on tenability or stability of all facilities that house occupants of reduced independent mobility. Such occupancies include but are not limited to elderly housing, healthcare facilities, schools, and daycare facilities.

401.2.4

The RI Building Code Board of Appeals shall review each application for such an installation where it or its associated docking facilities are located on state land, coastal land, state waters, or fill areas formerly part of state waters.

404.1 Delete 404.1 and substitute the following:

404.1 Prohibited locations. Piping shall not be installed in or through a circulating air duct, clothes chute, chimney or gas vent, ventilating duct, dumbwaiter or elevator shaft.