

**The Fire Safety Code Board of Appeal & Review met in the Conference Room of the Fire Board Headquarters, located at 272 West Exchange Street, Providence, RI on Thursday, January 5, 2006 at 1:00 PM. Present were Chairman George Farrell, Vice Chairman Coutu and Commissioners Blackburn, Preiss, Pearson and Burlingame. Also present were Executive Director Thomas Coffey, Jr., Esq. and Assistant Administrative Officer Carol Marsella. The following appeal was considered.**

**Appeal #060001: DEM Division of Planning and Development, for the property located on Interstate 295, Blackstone River State Park in Lincoln. Appearing for DEM was Chief Robert Sutton and appearing for the State Fire Marshal's office was Chief Deputy R. Michael DiMascolo. Commissioner Burlingame made a motion, seconded by Commissioner Pearson, to authorize the State Fire Marshal's office the ability to issue a temporary certificate of occupancy for this facility, which will be known as the Blackstone River State Park Visitors' Center. The Board also granted a time variance in order to allow the Applicant to install additional sprinkler coverage within ten days from the date of the hearing. The fire alarm system, the kitchen hood and suppression systems and the previously installed sprinkler system are fully functional and compliant. The Chief of the Albion Fire District had no objection. The motion was unanimous.**

**Respectfully submitted,**

**Carol Marsella**