

The Fire Safety Code Board of Appeal & Review met in Conference Room 109 at 260 West Exchange Street, Providence, RI on Tuesday, May 9, 2006 at 1:00 PM. Present were Vice Chairman Coutu and Commissioners Richard, Blackburn, Preiss, Filippi, Newbrook, Pearson, O'Connell and Burlingame. Also present were Executive Director Thomas Coffey, Jr., Esq. and Assistant Administrative Officer Carol Marsella. The following appeals were considered.

Appeal #060611: Ms. Stacey Trumonti for the property located at 596 Airport Road, Warwick. DSFM Cynthia Dehler and Wade Pallazini appeared for the State fire Marshal's Office. Commissioner Newbrook made a motion, seconded by Commissioner Blackburn, to grants the Applicant's request for a one-time change of use with any conditions set by the State Fire Marshal's office. The motion passed over the opposition vote of Commissioner Burlingame.

Appeal #050314A and 050315A: The Bristol Fourth of July Band Committee, for the property located at 574 Hope Street, Bristol and 199 Chestnut Street, Bristol. Chief Martin appeared for the Bristol Fire Marshal's office. Commissioner Newbrook made a motion, seconded by Commissioner Richard, to approve an annual change of use for the overnight occupancy of the school gymnasium to house out of state bands for the fourth of July parade, with any conditions set forth by the AHJ. The motion was unanimous.

Appeal #060584: Mr. Thomas Jellison for the property located at 89

Bellows Street, Warwick. ADSFM George Potter appeared for the Warwick Fire Marshal's office. Commissioner Blackburn made a motion, seconded by Commissioner Pearson, to grant the following relief. The Applicant's facility will be re-inspected by the AHJ to determine if the building requires sprinklers. If not, the heads in the clean room may be deleted, and a limited sprinkler system may be maintained. If sprinklers are required in this facility, the Applicant may utilize another option for clean room coverage, installed at the direction and to the satisfaction of the Warwick Fire Marshal's office. The motion was unanimous.

Appeal #060225: Mr. Paulo Oliveira, for the property located at 2375 South County Trail, East Greenwich. ADSFM Susan Hawksley appeared for the East Greenwich Fire Marshal's office, and William Howe, Chief of Inspections appeared for the State Fire Marshal's office. Commissioner Blackburn made a motion, seconded by Commissioner Newbrook, to deny the Applicant's request to eliminate sprinkler heads in the passenger elevator serving the new lobby, based on the provisions of NFPA 13. The motion was unanimous.

Appeal #060231: Mr. Keith Souza for the property located at 400 Main Street, Pawtucket. ADSFM Jeffrey Johnson appeared for the Pawtucket Fire Marshal's office. Commissioner Blackburn made a motion, seconded by Commissioner Filippi, to grant the Applicant request for a variance to allow the shared egress to remain, and to

allow the cited ceiling height to remain at 83 inches in this existing building, pending receipt by the Pawtucket Fire Marshal's office of the Applicant's letter stating that this facility will be owner occupied. The File will remain open. The motion was unanimous.

Respectfully submitted,

Carol Marsella