

The Joint Committee on the Rehabilitation Building and Fire Code for Existing Buildings and Structures met in Conference Room 109 located at 260 West Exchange Street, Providence, RI on Tuesday, February 20, 2007 at 2:30 PM. Present were Chairman Coutu, Vice Chairman Newbrook and Commissioners Preiss, Blackburn, Burlingame and Gagnon. Also present were Executive Secretary Thomas Coffey, Esq. and Assistant Administrative Officer Carol Marsella. The following appeals were considered.

APPEAL #R030006: Mr. Mark Van Noppen, for the property located at 166 Valley Street, Providence. (Building 6A) Lt. Richard Silva appeared for the Providence Fire Marshal's office. Commissioner Burlingame made a motion, seconded by Commissioner Gagnon, to grant the Applicant's request not to provide the cited dampers conditioned upon the installation of sprinkler heads in the shaft. The Applicant's plan of action was approved and there was no objection by the Providence Fire Marshal's office. The motion was unanimous.

APPEAL R060012: Mr. Frank Murphy, for the property located at 754 Broad Street, Providence. ADSFM George Calise appeared for the Providence Fire Marshal's office. Commissioners Burlingame and Blackburn recused themselves from consideration of this case. It was determined that this case should be held over until the April Rehab Code Board meeting. No action was taken at this time.

Respectfully submitted,

Carol Marsella