

**The Joint Committee on the Rehabilitation Building and Fire Code for Existing Buildings and Structures met at their headquarters located at 1 Regan Court, Varley Building #46, in Cranston, RI on Tuesday, April 8, 2014 at 2:30 P.M. Present were Chairman Newbrook, Vice Chairman Bernard and Commissioners Stillings, Turner, Pearson, Pimentel, Jackson and Blackburn. Commissioners Richard and Preiss were absent. Also present were Peter Dennehy Esq., and Administrative Assistant Desiree Campanini.**

**APPEAL TO BE HEARD:**

**APPEAL R#140005: Steeltex, Inc., for the property located at 1153 Westminster Street, Providence. ADSFM Richard Vespia appeared for the Providence Fire Marshal's Office. Commissioner Blackburn made a motion, seconded by Commissioner Pimental, to accept the Applicant's proposed plan of action and grant the Applicant a time variance of sixty (60) days to bring this facility into compliance. The Applicant was advised by the Board that he must maintain a fire watch in this facility until a fully compliant fire alarm is installed. The Board granted the Providence Fire Marshal's Office the authority to extend the above deadline, if a good faith effort is being made by the Applicant. The motion was unanimous.**

**Respectfully submitted**

**Desiree Campanini**

# **Administrative Assistant**